

Fire Application #245515 - GoDaddy TI

[illegible]



Fire Application #245515 - GoDaddy TI

Project Contact

Company Name: ARCHER CONSTRUCTION INC

Name: Ted Queen

Email: tqueen@archerconstruction.com

Address: 7855 S 206TH ST
Kent WA 98032

Phone #: (206) 293-2184

Project Type

Nonresidential

Activity Type

Alteration

Scope of Work

Fire Sprinkler Systems

Project Name: GoDaddy TI

Description of Work: Modify existing overhead fire sprinkler system to accommodate new office TI walls and ceilings.

Project Details

System Information

This is an addition to an existing system

Fire System Type

NFPA 13

Alterations

There are alterations to devices or systems.

Quick Response or Recalled Head Change Out

The K-Factor and spacing match existing.

Quick Response or Recalled Head Relocation

Heads are being relocated.

Change of Use

This is not a change of use.

Hydraulic Calculations

There is no change to the hydraulic calculations.

Hazard Classification

The space is classified as Light/Ordinary Hazard.

Mains and Cross Mains

Mains or cross mains are not being relocated.

Heads - Excluding Quick Response and Recalled

101 - 1000 total heads

Fire System Counts

Number of Heads Added 94

Number of Heads Relocated 32